

Independent Pricing and Regulatory Tribunal

# Method Guide Commercial Lighting Energy Savings Formula

**Deemed Energy Savings Method** 

Energy Savings Scheme December 2015 © Independent Pricing and Regulatory Tribunal of New South Wales 2015

This work is copyright. The *Copyright Act 1968* permits fair dealing for study, research, news reporting, criticism and review. Selected passages, tables or diagrams may be reproduced for such purposes provided acknowledgement of the source is included.

Inquiries regarding this document should be directed to:

ESS Enquiries (02) 9290 8452 or ESS@ipart.nsw.gov.au

Independent Pricing and Regulatory Tribunal of New South Wales PO Box K358, Haymarket Post Shop NSW 1240 Level 15, 2-24 Rawson Place NSW 2000 T (02) 9290 8400 F (02) 9290 2061 www.ipart.nsw.gov.au

#### **Document Control**

| Version number | Change description  | Date published   |
|----------------|---|------------------|
| V1.0           | Initial release – following gazettal of ESS<br>Rule Amendment No.2  | 18 July 2014     |
| V1.1           | Change in Chapter 2 to advise that guidance for roads and public spaces will be available soon  | 5 August 2014    |
| V2.0           | Application Form: Part B – Method Details<br>and Nomination Form removed from the<br>Method Guide to be separate documents.   | 19 January 2015  |
| V3.0           | Consultation draft: Inclusion of guidance<br>related to Lighting for Roads and Public<br>Spaces, clarifications regarding service<br>levels, performance requirements and BCA<br>classification of building/spaces. | 20 August 2015   |
| V3.1           | Inclusion of guidance related to Lighting for<br>Roads and Public Spaces, clarifications<br>regarding service levels, performance<br>requirements and BCA classification of<br>building/spaces.                     | 22 December 2015 |

# Contents

| 1  | Abo   | ut this document   | 1  |
|----|-------|--|----|
|    | 1.1   | Legislative requirements   | 1  |
|    | 1.2   | Related documents  | 2  |
| 2  | Туре  | es of activities the method can be applied to  | 2  |
|    | 2.1   | Building lighting  | 2  |
|    | 2.2   | Lighting for roads and public spaces   | 3  |
| 3  | Req   | uirements that must be met to create ESCs  | 3  |
|    | 3.1   | Energy saver   | 3  |
|    | 3.2   | Purchaser  | 4  |
|    | 3.3   | Implementation and implementation date   | 5  |
|    | 3.4   | Lighting equipment   | 5  |
|    | 3.5   | Electrical work  | 6  |
|    | 3.6   | Minimum training requirements  | 6  |
|    | 3.7   | Service levels   | 7  |
|    | 3.8   | Relationships to representatives   | 11 |
|    | 3.9   | Engaging with customers  | 12 |
|    | 3.10  | Insurance  | 13 |
| 4  | Calc  | ulation of energy savings  | 13 |
|    | 4.1   | Inputs to the equations  | 14 |
|    | 4.2   | Calculation Tools  | 14 |
|    | 4.3   | Calculating energy savings from projects that include upgrades to both building and road/public space lighting | 15 |
|    | 4.4   | How are ESCs created under the method?   | 15 |
|    | 4.5   | How do you apply for accreditation to create ESCs using the method?  | 15 |
| 5  | Glos  | sary   | 17 |
| Ар | pendi | ces  | 18 |
|    | A     | Building Code of Australia (Part A3 – Classification of Buildings and Structures)                              | 20 |
|    | В     | List of relevant standards in the AS/NZS Series  | 24 |
|    | С     | Equations and inputs to Commercial Lighting Energy Savings Formula calculations                                | 26 |
|    | D     | Tables from the ESS Rule   | 29 |

# 1 About this document

Under the Energy Savings Scheme (ESS), electricity retailers and other mandatory participants (Scheme Participants) are obliged to meet energy savings targets.

The ESS reduces electricity consumption in NSW by creating financial incentives for organisations to invest in energy savings projects. Energy savings are achieved by Accredited Certificate Providers (ACPs) installing, improving or replacing energy savings equipment. Companies that become ACPs can create energy savings certificates (ESCs) by carrying out these activities and then sell those ESCs to Scheme Participants. The Independent Pricing and Regulatory Tribunal of NSW (IPART) is both the Scheme Administrator and Scheme Regulator of the ESS.<sup>1</sup>

This guide details how the Commercial Lighting Energy Savings Formula method (the method) of the ESS operates, the eligibility requirements to use the method, and how to calculate the energy savings. This guide should be used by:

- ▼ applicants seeking accreditation, to assist them in completing their application, and
- ▼ those persons already accredited (ACPs), to assist them in accurately calculating energy savings using this method.

Please refer to this guide to complete the *Application Form: Part B – Method Details* – *Commercial Lighting Energy Savings Formula* (Application Form: Part B – Method Details)<sup>2</sup> which can be found on the ESS website.

## 1.1 Legislative requirements

This document is a guide only and is not legal advice. The legal requirements for ACPs participating in the ESS are set out in:

- ▼ Part 9 of the *Electricity Supply Act* 1995 (Act)
- ▼ Part 6 of the Electricity Supply (General) Regulation 2014 (Regulation), and
- ▼ the Energy Savings Scheme Rule of 2009 (ESS Rule).

ACPs are also required to meet any additional requirements in their Accreditation Notice.

<sup>&</sup>lt;sup>1</sup> Under sections 153(2) and 151(2) of the Act, respectively

<sup>&</sup>lt;sup>2</sup> The Application Form: Part B - Method Details - Commercial Lighting Energy Savings Formula can be found on the ESS website at: http://www.ess.nsw.gov.au/How\_to\_apply\_for\_accreditation/Apply\_now\_-\_guides\_and\_application\_forms

# 1.2 Related documents

As noted throughout this guide, the following documents and tools provide further information and assistance on the method:

- Evidence Manual Commercial Lighting Energy Savings Formula
- Building Lighting Information Sheet
- Commercial Lighting Calculation Tool

You can also contact the Scheme Administrator if you have further questions or need assistance in applying the calculation tool.

# 2 Types of activities the method can be applied to

The method can be used to calculate energy savings and create ESCs from the following activities:

- upgrades of building lighting
- upgrades of lighting for roads and public spaces, and
- upgrades of lighting for traffic signals.

This guide covers upgrades of building lighting and lighting for roads and public spaces only. If you plan to apply for accreditation for upgrades of lighting for traffic signals, please contact the Scheme Administrator.

# 2.1 Building lighting

Building lighting is defined as lighting equipment affixed to commercial/industrial premises that are classified under the Building Code of Australia (BCA)<sup>3</sup> as:

- Class 3, 5, 6, 7, 8, 9 or 10(b) buildings, or
- the common areas of a Class 2 building.

Refer Appendix A for more information on building classifications.

Effectively, this means the method can be applied to lighting upgrades at most non-residential premises – including industrial facilities, public facilities (such as schools and health centres), office buildings, and shopping centres. Additionally the method can be applied to lighting upgrades in stairways, corridors and shared areas of multiple unit residential buildings such as apartment buildings.

<sup>&</sup>lt;sup>3</sup> The Building Code of Australia (BCA) forms Part 1 and Part 2 of the National Construction Code (NCC).

## 2.2 Lighting for roads and public spaces

Lighting for roads and public spaces is defined as lighting covered by the *AS/NZS 1158: Lighting for Roads and Public Spaces* standard series. Effectively, this means the method can be applied to lighting upgrades on roads<sup>4</sup> located between the boundaries of adjoining properties (ie, outside the boundaries of any private property) and in outdoor spaces of a public nature (eg, public squares, parks, beaches, etc).

The AS/NZS 1158 series defines two main categories of lighting for roads and public spaces:

- Category V Lighting (Vehicular traffic). This is lighting for roads where the visual requirements of motorists are dominant – eg, traffic routes. This category includes subcategories ranging from V1 to V5, which relate to the level of traffic on the road among other things.
- Category P Lighting (Pedestrian Areas). This is lighting for roads and other outdoor public spaces where the visual requirements of pedestrians are dominant – eg, local roads, outdoor shopping precincts, or outdoor carparks.<sup>5</sup>

The appropriate lighting category, subcategory and requirements for the particular road or public space your RESA relates to must be determined by (or in consultation with) the appropriate authority concerned (eg, road and traffic authorities, local councils, Railcorp, etc).

The lighting equipment installed as part of the lighting upgrade must comply with all parts of the AS/NZS 1158 series that are applicable to the road or public space where the upgrade will take place.<sup>6</sup>

# 3 Requirements that must be met to create ESCs

To create ESCs using the method, you must meet the range of requirements outlined below.

## 3.1 Energy saver

You must be an ACP who is also an energy saver. You can be either:

<sup>&</sup>lt;sup>4</sup> Road is defined as the right of way between boundaries of adjoining properties. It could include laneways, pathways, footpaths, etc. Please refer to the AS/NZS 1158.0 Standard for the definition.

<sup>&</sup>lt;sup>5</sup> Please refer to AS/NZS 1158 Standard for the complete listing of all subcategories.

<sup>&</sup>lt;sup>6</sup> Clause 9.4.1 (b) requires that the lighting upgrade meets or exceed the relevant lighting standard for each upgrade, to the satisfaction of the Scheme Administrator.

- the original energy saver which, under the method, is the purchaser of the relevant lighting equipment (as defined in section 3.2), or
- the nominated energy saver which is someone the purchaser has nominated as the energy saver by completing a form generated from the method-specific Nomination Form Template.<sup>7</sup>

If you are the nominated energy saver for multiple purchasers, you must also document your procedure for engaging with these purchasers to obtain their energy saver nominations.

## 3.2 Purchaser

As noted above, to be the original energy saver you must be the purchaser. To be the purchaser, you must:

- purchase or lease the lighting equipment or service that results in the energy savings
- directly benefit from the end-use services provided by this lighting equipment (see section 3.2.1 for more information), and
- contribute a net amount of at least \$5 (excluding GST) per megawatt hour (MWh) of energy savings towards cost of the lighting upgrade (see section 3.2.2), and have evidence to support this.

# 3.2.1 Directly benefit from the end-use services provided by the lighting upgrade

The purchaser must directly benefit from the end-use services provided by the upgraded building lighting or upgraded lighting for roads and public spaces.

For upgrades to building lighting, this generally means that the purchaser must be someone who regularly uses the lighting equipment, such as the occupier of the premises. It may also be:

- The landlord of the premises, who may directly benefit by "making available lighting at a leased premises". The Scheme Administrator has specified this service to be an end-use service for the purposes of Table A.17 of the ESS Rule.<sup>8</sup>
- The body corporate responsible for the lighting in the common areas of a building. In this case, the body corporate may directly benefit as its members regularly use the lighting system in the common areas.

<sup>&</sup>lt;sup>7</sup> The Nomination Form Template can be found on the ESS website at: www.ess.nsw.gov.au /Methods\_for\_calculating\_energy\_savings/Commercial\_Lighting.

<sup>8</sup> Scheme Administrator Notice 1/2014: www.ess.nsw.gov.au/Notices\_Events\_and\_Updates/ESS\_Notices/Scheme\_Administrator\_Not ice\_012014\_Additional\_End-Use\_Services

For upgrades to lighting for roads and public spaces, it generally means that the purchaser must be the authority that determined the appropriate lighting requirements for the particular road or public space (or was consulted in determining these requirements).

# 3.2.2 Contribute a net amount of at least \$5 per MWh towards the cost of the lighting upgrade

The purchaser must contribute a net amount of **at least** \$5 (excluding GST) per MWh of energy savings towards the cost of the lighting upgrade. For example, if the upgrade creates 50 MWh of energy savings, the purchaser must contribute **a minimum** of \$250 (excluding GST) (ie, \$5 x 50 MWh).<sup>9</sup>

# 3.3 Implementation and implementation date

Under the method:

- **an implementation** is the delivery of a lighting upgrade at a site,
- the implementation date is the date the lighting upgrade is completed as supported by evidence.

To create ESCs you must be registered as an ACP **before** the implementation date.<sup>10</sup> If you are the nominated energy saver, you must be nominated by the original energy saver/purchaser **on or before** the implementation date.

# 3.4 Lighting equipment

You can replace, modify or install lighting equipment that is classed as 'standard' equipment for lighting upgrades under the ESS. The standard equipment classes are listed and defined in Appendix D, Table A9.1 of this guide. Each class has a default Lamp Circuit Power (LCP) value, listed in Appendix D, Table A9.2. The LCP values are used to calculate the energy savings.

Alternatively, you may replace, modify or install certain 'other' lighting equipment, provided it is eligible and is accepted as meeting specified equipment requirements. The other equipment classes and their LCP values and requirements are listed and defined in Appendix D, Table A9.3 and Table A9.4. If you plan to use any of these other equipment classes, you should first read the

<sup>&</sup>lt;sup>9</sup> Where you are the nominated energy saver and the lighting upgrade costs more than \$5 per MWh of energy savings, you may require the purchaser to make more than this minimum contribution, or you may choose to absorb the additional costs.

<sup>&</sup>lt;sup>10</sup> The ESS website provides information on applying to become an ACP at: www.ess.nsw.gov.au/How\_to\_apply\_for\_accreditation.

# *Lighting Equipment Requirements – LED Lighting, Induction Lamps and Emerging Lighting Technologies Guide.*<sup>11</sup>

Lighting control systems, such as occupancy sensors, can be installed to reduce electricity consumption by reducing light output when it is not required. You can install these control systems as a standalone upgrade to existing lighting, or as part of a larger lighting refurbishment involving the equipment above.

You must not install or replace T5 Adaptor Kits or Retrofitted Luminaires – LED Linear Lamps as part of the lighting upgrade, as these equipment classes are ineligible under the method.

#### 3.4.1 Equipment requirements for lighting for roads and public spaces

If you replace and modify lighting for roads and public spaces, the equipment must meet the requirements specified by the standards below:

- ▼ *AS/NZS* 60598.1.1 *Luminaires General requirements and tests,* and
- AS/NZS 60598.2.3 Luminaires Particular Requirements Luminaires for road and street lighting (for Category V lighting – Vehicular Traffic)<sup>12</sup>

If you use equipment in the class **"LED Luminaire – Street light"** (listed in Table A9.3), it must also be accepted under our current Emerging Lighting Technology (ELT) Process.<sup>13</sup>

#### 3.5 Electrical work

You must ensure that all electrical work involved in the lighting upgrade is performed by appropriately trained persons and undertaken or completed under the supervision of a licensed electrician. This requirement applies even when the lighting upgrade does not require any wiring work to be conducted or otherwise require an electrician to be present.

#### 3.6 Minimum training requirements

You must comply with ESS Notice 01/2013 - Minimum requirements for conduct of persons acting on behalf of Accredited Certificate Providers – v2.0 July 2014.<sup>14</sup> We may

<sup>&</sup>lt;sup>11</sup> The Lighting Equipment Requirements – LED Lighting, Induction Lamps and Emerging Lighting Technologies Guide can be found on the ESS website at: www.ess.nsw.gov.au /Projects\_and\_equipment/Lighting\_Technologies/Using\_Lighting\_Technologies\_for\_Commer cial\_Lighting.

 $<sup>^{12}</sup>$   $\,$  As required by Clause 2.11.1 (a) of AS/NZS 1158.1.1  $\,$ 

<sup>&</sup>lt;sup>13</sup> More information on how to apply for an ELT to be accepted for use under the ESS can be found here: www.ess.nsw.gov.au/Projects\_and\_equipment/Lighting\_Technologies

publish additional training requirements for installers of building lighting or lighting for roads and public spaces from time to time.

#### 3.7 Service levels

You must only create ESCs from lighting upgrades that reduce electricity consumption **without** reducing service levels (including safety levels) below the pre-upgrade levels.<sup>15</sup> For example, you cannot create ESCs from activities that reduce electricity only by the de-lamping of a particular area as this would also reduce service levels.

#### 3.7.1 Performance requirements

You must satisfy the minimum performance requirements for upgrades of building lighting and upgrades of roads and public spaces (outlined below), to the satisfaction of the Scheme Administrator. We may publish additional minimum performance requirements for these upgrades from time to time.

#### 3.7.2 Performance requirements for upgrades of building lighting

For upgrades of building lighting:

- ▼ the lighting for each space must satisfy the relevant requirements of AS/NZS 1680 or, where this standard is not applicable, another benchmark agreed to in advance by the Scheme Administrator
- the upgraded lighting system must comply with the requirements of the BCA section F4.4 Safe Movement
- the upgraded lighting system must have an Illumination Power Density (IPD) for each space less than or equal to the maximum IPD allowed under BCA part J6, and
- the original energy saver must be provided with a completed and signed Building Lighting Information Sheet on completion of the lighting upgrade.

#### AS/NZS 1680 – building lighting

Upgrades of building lighting must achieve the relevant requirements of AS/NZS 1680. These may include, but are not limited to, the requirements related:

<sup>&</sup>lt;sup>14</sup> The ESS Notice 01/2013 - Minimum requirements for conduct of persons acting on behalf of Accredited Certificate Providers - v2.0 July 2014 is available on the ESS website at: www.ess.nsw.gov.au/Events\_and\_Updates/ESS\_Notices.

<sup>&</sup>lt;sup>15</sup> Clause 5.3(b) of the ESS Rule.

- maintained illuminance accounting for lumen depreciation
- control of glare, and
- uniformity of illuminance.

Further information about each of these requirements can be found in AS/NZS 1680.

In addition, AS/NZS 1680 includes specific requirements for a range of lighting upgrades. At a minimum, you must satisfy the requirements related to:

- Correlated Colour Temperature<sup>16</sup> and matching existing lighting
- ▼ Colour Rendering Index<sup>17</sup> in order to accurately portray colour
- glare, in order to avoid 'disability glare' and 'discomfort glare'
- ▼ reflectance off surfaces, and
- ▼ daylight effects.

Compliance with the relevant requirements may be checked at the time of audit, so it is advisable to involve the person responsible for providing the lighting solution and upgrade in:

- assessing how these requirements apply to the lighting upgrade, and
- ensuring that the lighting upgrade satisfies the requirements.

#### Other benchmarks where AS/NZS 1680 does not apply

Where the lighting upgrade is outside the scope of AS/NZS 1680, you may apply to the Scheme Administrator to use another performance benchmark. Your application must include:

- the nature of the lighting upgrade
- why AS/NZS 1680 does not apply
- what benchmark or alternative standard you propose to use to ensure service levels are appropriate, and
- ▼ how each space will meet, as a minimum, the requirements of BCA Section F4.4, 'Safe Movement'.

Compliance with the performance requirements of the agreed benchmark may be checked at the time of audit, so it is advisable to prepare your application in consultation with the person responsible for providing the lighting solution and upgrade.

<sup>&</sup>lt;sup>16</sup> Correlated Colour Temperature is a measurement of the apparent colour of the light source.

<sup>&</sup>lt;sup>17</sup> Colour Rendering Index is a measurement of how accurately a light source can portray the colour of an object in comparison to an ideal light source such as an incandescent lamp.

#### **Building Lighting Information Sheet**

As an ACP, you must provide the energy saver with the *Building Lighting Information Sheet*,<sup>18</sup> completed with your contact details. The *Building Lighting Information Sheet* replaces the previous 'Energy saver Information Sheet' and must be provided on completion of the lighting upgrade.

Once the lighting upgrade is implemented, you also need to sign the Lighting Quality Statement (statement) that is attached to the Building Lighting Information Sheet. The statement confirms that the lighting upgrade satisfies all relevant lighting requirements. The statement must then be co-signed by the purchaser. You also need to attach a recommended Maintenance Schedule to the statement. This Maintenance Schedule must be provided by the party responsible for the lighting installation ('lighting upgrades solution provider'), which may be you, or an installer you are working with.

You must keep the signed statement and maintenance schedule as evidence supporting your ESC claim. Both will be checked at audit and may be checked by us.

#### Building Code of Australia requirements

To calculate energy savings from building lighting upgrades, you need to understand the Building Code of Australia (BCA) requirements that apply to lighting – particularly the requirements described in Part J6 and Section F4.4.

After implementation, the lighting upgrade must achieve an Illumination Power Density (IPD) that is less than or equal to the maximum IPD for each space, as defined in Part J6 of the BCA. In addition, each space must meet the BCA Section F4.4, 'Safe Movement' requirements. These may be updated from time to time.

Further information about how BCA requirements apply to the calculation of energy savings is provided in the *Evidence Manual Commercial Lighting Energy Savings Formula* (Evidence Manual).<sup>19</sup>

# 3.7.3 Performance requirements for upgrades of lighting for roads and public spaces

All upgrades of lighting for roads and public spaces must meet the requirements necessary to facilitate the safe movement of vehicles and pedestrians. These requirements are specified in the relevant parts of AS/NZS 1158.

<sup>&</sup>lt;sup>18</sup> The Building Lighting Information Sheet is available on the ESS website at: www.ess.nsw.gov.au/Methods\_for\_calculating\_energy\_savings/Commercial\_Lighting.

<sup>&</sup>lt;sup>19</sup> The *Evidence Manual* is available on the ESS website at: www.ess.nsw.gov.au/Methods\_for\_calculating\_energy\_savings/Commercial\_Lighting

In addition to facilitating the safe movement of vehicles and pedestrians, you need to consider the other objectives of public lighting:

- discouraging illegal acts, and
- improving the amenity of an area through increased aesthetic appeal.

You will also need to meet the requirements of AS/NZS 1158 for implementations related to these objectives where relevant.

#### Relevant parts of AS/NZS 1158

The parts of AS/NZS 1158 that are applicable to the lighting upgrade will depend on the lighting category, subcategory and performance requirements of the particular road or public space involved. As noted above, these are matters that must be determined by or in consultation with the responsible authority<sup>20</sup>.

These parts may include:

- ▼ AS/NZS 1158.0 Introduction
- ▼ AS/NZS 1158.1.1 Vehicular Traffic (Category V) lighting Performance and design requirements
- ▼ AS/NZS 1158.1.2 Vehicular Traffic (Category V) lighting Guide to design, installation, operation and maintenance
- AS/NZS 1158.2 Computer procedures for the calculation of light technical parameters for Category V and Category P lighting
- AS/NZS 1158.3.1 Pedestrian Area (Category P) lighting Performance and design requirements
- ▼ AS/NZS 1158.4 Lighting for pedestrian crossings
- ▼ AS/NZS 1158.5 Tunnels and underpasses
- ▼ SA/SNZ TS 1158.6 Luminaires Performance

The documentation required for demonstrating compliance with the AS/NZS 1158 series is specified in an appendix of the relevant standard. In particular, the documentation related to:

- vehicular lighting (category V lighting) is specified in Appendix D of AS/NZS 1158.1.1
- ▼ pedestrian lighting (category P lighting) is specified in Appendix E of AS/NZS 1158.3.1

<sup>&</sup>lt;sup>20</sup> Most authorities responsible for public lighting in NSW (eg, Electricity Distributors, local councils and RailCorp) maintain their own requirements they've deemed necessary including elements of AS/NZS 1158. Demonstrated compliance with such requirements would generally indicate compliance with the relevant requirements of AS/NZS 1158.

▼ pedestrian crossing lighting (category PX) is specified in Appendix D of AS/NZS 1158.4.

ACPs are required to collect and retain the documentation described in the appendices applicable to each lighting upgrade to demonstrate that the upgrade is compliant with the requirements laid out in the AS/NZS 1158 series. This documentation will be checked at audit.

### 3.8 Relationships to representatives

As an ACP, you are responsible for all lighting upgrade activities conducted on your behalf by your representatives, including third parties. You must meet all requirements of the Scheme including those outlined below.

#### 3.8.1 Representatives

Your representative includes any person conducting any aspect of a lighting upgrade for which ESCs will be created, who is:

- your employee or direct contractor
- an employee or direct contractor of another company or business that has a legally binding contract with you, or
- a volunteer who has a direct, documented and legally binding agreement with you.

A representative must be aged 18 years or over.

Where a customer wants its own staff or contractors to undertake the activity, or part of the activity (eg, the customer has a qualified electrician on staff who will install the lighting equipment), you must conduct a site brief prior to the activity taking place. At a minimum, the site brief must inform the customer's staff of any Scheme requirements that they must address.

#### 3.8.2 Contracts

You are required to have a formal, documented and enforceable contract or agreement with all your representatives (as defined above).<sup>21</sup>

This contract or agreement must include requirements relevant to the role performed by the representative, and must be signed before the representative conducts activities on your behalf.

<sup>&</sup>lt;sup>21</sup> As per the ESS Notice 01/2013 "Minimum requirements for conduct of persons acting on behalf of Accredited Certificate Providers" stipulated in clause 13 of the Accreditation Notice.

You must be able to provide evidence of any contract or agreement during an audit.

### 3.8.3 Registers

You must maintain a register of all representatives conducting ESS related activities on your behalf, or on behalf of the purchaser who has nominated you as the energy saver. The register must include:

- ▼ name
- contact details
- training and qualifications
- electrician's licence number (where applicable)
- ▼ relationship to the ACP or the purchaser (ie, employee or other representative)
- date of employment or commencement of contract, and
- responsibility for the representative to sign off on documents that will be kept as records for the lighting upgrade project.

# 3.9 Engaging with customers

You must ensure that any representative engaging with customers on your behalf is aware of their responsibilities under the ESS. For the purposes of this requirement, a 'customer' refers to the purchaser, or a potential purchaser.

Engaging with customers includes any aspect of the lighting upgrade where your employee or representative is discussing the ESS or your RESA with the customer.

#### 3.9.1 Training for representatives

To ensure awareness, you must provide all your representatives with the following information:

- an overview of the ESS
- ▼ an overview of your RESA
- any of your internal procedures relevant to the representative's role in your RESA, and
- relevant legislative or regulatory requirements in relation to the Scheme that your representative may need to address in performing their role (ie, provisions for telemarketing and door-to-door sales, occupational work health & safety, etc).

Where a customer wants its own staff or contractors to undertake the activity, or part of the activity (eg, the customer has a qualified electrician on staff who will install the lighting equipment), you must conduct a site brief prior to the activity taking place. At a minimum, this site brief must inform the customer's staff of any Scheme requirements that they must address.

#### 3.9.2 Customer complaints

You must have a documented procedure for handling customer complaints. It must include:

- how complaints are received
- where the complaints will be recorded
- who will address the complaints, and
- how the progress of the complaint will be tracked.

## 3.10 Insurance

You (and any agents/subcontractors<sup>22</sup> involved in the delivery of your RESA) must each be covered by Public Liability Insurance cover of at least \$5 million. Insurance cover of this amount must be maintained for the life of the RESA. Public Liability Insurance must, at a minimum, cover the replacement and/or rectification of customer property damaged as a result of work performed by you and/or your subcontractors or agents.

Either you or your agents/subcontractors must also hold Product Liability Insurance of at least \$5 million that covers all products used in your RESA.

As an ACP, you must also:

- provide us with current certificates of your, and your subcontractors'/agents', Public Liability and Product Liability Insurances, within seven days of each renewal, reissue or change of policy, and
- maintain a register of subcontractors/agents that contains copies of their Public Liability Insurance and, if relevant, their Product Liability Insurance.

Compliance with these requirements will be checked at the time of audit.

# 4 Calculation of energy savings

The energy savings resulting from an upgrade of building lighting or lighting for roads and public spaces are calculated using:

- equations 6, 9 and either equation 7 or equation 8 from the ESS Rule, and
- the relevant tables from Schedule A of the ESS Rule.

<sup>&</sup>lt;sup>22</sup> That is, any company you are working with involved directly in the installation of lighting equipment.

You can find the equations and the relevant tables from Schedule A of the ESS Rule in Appendices C and D of this guide.

## 4.1 Inputs to the equations

All inputs to the equations are provided in Appendix C of this guide, and are explained in detail in the Evidence Manual for the method.<sup>23</sup>

# 4.2 Calculation Tools

A *Commercial Lighting Calculation Tool*<sup>24</sup> is available on the ESS website to assist you in calculating energy savings under the method. You should use the Commercial Lighting Calculation Tool when equation 7 of the ESS Rule is applicable to the calculation of the baseline energy consumption of the lighting upgrade, ie:

- Use the Commercial Lighting Calculation Tool if:
  - the lighting upgrade is part of a refurbishment that would **not** otherwise have been required to comply with the BCA Part J6, or
  - the lighting upgrade is part of a refurbishment that **would** otherwise have been required to comply with the BCA Part J6, and the existing lighting has an IPD that is less than or equal to the maximum IPD allowed under the BCA Part J6.
- Use the Commercial Lighting Calculation Tool if the lighting upgrade is part of a refurbishment that is required to comply with the AS/NZS 1158 (ie, for lighting for roads and public spaces).
- <u>Do not</u> use the Commercial Lighting Calculation Tool if:
  - the lighting upgrade is part of a refurbishment that **would** have been required to comply with the BCA Part J6, **and**
  - the existing lighting has an IPD that is greater than the maximum IPD allowed under the BCA Part J6.

In this last instance, the ESS Rule requires the use of equation 8 to determine the baseline energy consumption of the lighting upgrade, which is not supported by the Commercial Lighting Calculation Tool. You must contact the Scheme Administrator when undertaking this type of upgrade for further guidance.

You can develop your own calculation tool if you wish, but we recommend you calibrate its outputs against the Scheme Administrator tool.

<sup>&</sup>lt;sup>23</sup> The Evidence Manual is available on the ESS website at:

http://www.ess.nsw.gov.au/Methods\_for\_calculating\_energy\_savings/Commercial\_Lighting
 <sup>24</sup> The Commercial Lighting Calculation Tool is available on the ESS website at: www.ess.nsw.gov.au/Methods\_for\_calculating\_energy\_savings/Commercial\_Lighting

If you need assistance in using the Commercial Lighting Calculation Tool, contact the Scheme Administrator for further guidance.

# 4.3 Calculating energy savings from projects that include upgrades to both building and road/public space lighting

If a particular implementation includes a combination of Building Lighting and Lighting for Roads and Public Spaces, you must calculate energy savings for each space separately.

If you are using the calculation tool provided by the Scheme Administrator, you must use the different functionality provided by the tool for the implementation separately:

- one version of the tool with the functionality to calculate energy savings from all spaces classified as 'Building Lighting', and
- another version of the tool with the functionality to calculate energy savings from all 'Lighting for Roads and Public Spaces' areas.

Spaces classified as Building Lighting must comply with the requirements for Building Lighting, and areas classified as Lighting for Roads and Public Spaces must comply with the requirements for Lighting for Roads and Public Spaces.

## 4.4 How are ESCs created under the method?

The Evidence Manual for the method provides instructions on how to register ESCs and defines the requirements for keeping records that verify the energy savings achieved.

The Evidence Pack<sup>25</sup> that accompanies the Evidence Manual can be used to record and store data to meet these requirements.

# 4.5 How do you apply for accreditation to create ESCs using the method?

For you or your organisation to become an ACP and generate ESCs from projects that use the Commercial Lighting Energy Savings Formula method, you need to complete an application that is tailored to this method.

An application has multiple parts, which are explained in the *Application Guide for ESS Accreditation* (Application Guide).<sup>26</sup> As a minimum, you will have to provide:

<sup>&</sup>lt;sup>25</sup> The Evidence Pack is available on the ESS website at: http://www.ess.nsw.gov.au/Methods\_for\_calculating\_energy\_savings/Commercial\_Lighting

- Application Form: Part A General Details,<sup>27</sup> and
- Application Form: Part B Method Details.<sup>28</sup>

A full explanation of the application process is provided in the Application Guide.

<sup>&</sup>lt;sup>26</sup> The Application Guide for ESS Accreditation is available on the ESS website at: http://www.ess.nsw.gov.au/How\_to\_apply\_for\_accreditation/Apply\_now\_-\_guides\_and\_application\_forms

<sup>27</sup> The Application Form: Part A - General Details is available on the ESS website at: http://www.ess.nsw.gov.au/How\_to\_apply\_for\_accreditation/Apply\_now\_-\_guides\_and\_application\_forms

<sup>&</sup>lt;sup>28</sup> The Application Form: Part B - Method Details Commercial Lighting Energy Savings Formula is available on the ESS website at: http://www.ess.nsw.gov.au/How\_to\_apply\_for\_accreditation/Apply\_Now\_-\_Guides\_and\_Application\_Forms

# 5 Glossary

# Table 5.1 Commercial Lighting Energy Savings Formula Definitions

| Acronym                | Description   |  |
|------------------------|---|--|
| ACP                    | Accredited Certificate Provider   |  |
| BCA                    | Building Code of Australia. Also referred to as the National Construction Code (NCC)  |  |
| ESCs                   | Energy Savings Certificates   |  |
| ESS                    | Energy Savings Scheme   |  |
| Evidence Manual        | Evidence Manual – Commercial Lighting Energy Savings<br>Formula   |  |
| Evidence Pack          | Evidence and Certificate Registration Pack – Commercial<br>Lighting Energy Savings Formula  |  |
| Glare                  | Difficulty seeing in the presence of a very bright light and possibly causing discomfort or inability to see  |  |
| Implementation         | The delivery of a RESA to a particular site   |  |
| Implementation date    | The date when the lighting upgrade was completed  |  |
| IPD                    | Illumination Power Density  |  |
| Licensed electrician   | A person that holds a licence to carry out low voltage electrical<br>work in NSW without supervision, and is registered as an<br>electrical contractor to contract, or offer to contract, or to carry<br>out electrical installation work   |  |
| Lighting upgrade       | The replacement of existing general lighting End-User<br>Equipment (EUE) with new general lighting EUE that consumes<br>less electricity, or the modification of existing general lighting<br>EUE resulting in a reduction in the consumption of electricity<br>compared to what would have otherwise been consumed |  |
| IPART                  | Independent Pricing and Regulatory Tribunal – the Scheme<br>Administrator   |  |
| Illuminance            | The amount of light that falls on a surface per unit area, which is sometimes referred to as the "Lighting Level" (measured in Lux)   |  |
| LCP                    | Lamp Circuit Power  |  |
| Lumen                  | The unit of luminous flux, which is a measure of the total<br>amount of visible light emitted from a light source   |  |
| Lumen Depreciation     | The decrease in lumen output from a lamp over time  |  |
| Lux                    | The unit of Illuminance (1 lux equals 1 lumen per square metre (Im/m <sup>2</sup> )   |  |
| MWh                    | Megawatt hour (unit of energy)  |  |
| NLP                    | Nominal Lamp Power – the power consumption of a lamp excluding any external control gear  |  |
| Nominated energy saver | A person nominated to be the energy saver by the original<br>energy saver and satisfying the conditions of clause 5.2(b) of<br>the ESS Rule (see section 3.1)   |  |
| Original energy saver  | The person defined as the purchaser in clauses 9.4.3 and 9.4.4 of the ESS Rule with reference also to clause 5.2 of the ESS Rule (see section 3.2)  |  |
| RCP                    | Reflected Ceiling Plan  |  |
| RESA                   | Recognised Energy Saving Activity   |  |

Appendices

# A Building Code of Australia (Part A3 – Classification of Buildings and Structures)

Part A3 of the BCA – Volume 1 – 2014 classifies buildings and structures. Under the ESS, only premises in the following BCA classes are eligible for commercial lighting upgrades:

- ▼ Class 3, 5, 6, 7, 8, 9 or 10(b) buildings, or
- the **common areas**<sup>29</sup> of a Class 2 building.

Under Part A3.3 of the BCA "Multiple Classification", different areas within the same building may be classified in different BCA classes.

This appendix provides a transcript of Part A3 of the BCA.

#### PART A3 – Classification of Buildings and Structures

#### A3.1 - Principles of Classification

The classification of a building or part of a building is determined by the purpose for which it is designed, constructed or adapted to be used.

#### A3.2 - Classifications

Buildings are classified as follows:

Class 1: one or more buildings which in association constitute -

- (a) Class 1a a single dwelling being
  - (i) a detached house; or
  - (ii) one of a group of two or more attached dwellings, each being a building, separated by a *fire-resisting* wall, including a row house, terrace house, town house or villa unit; or
- (b) Class 1b -
  - (i) A boarding house, guest house, hostel or the like -

<sup>&</sup>lt;sup>29</sup> Please note that the ESS Rule defines "Common areas" as:

For buildings owned under strata title, the common property as defined in either the Strata Schemes (Freehold Development) Act 1973 (NSW), or Strata Schemes (Leasehold Development) Act 1986 (NSW); or

For buildings not owned under strata title (e.g., under company title), the non-residential property of BCA Class 2 buildings

- A. with a total area of all floors not exceeding 300 m<sup>2</sup> measured over the enclosing walls of the Class 1b; and
- B. in which no more than 12 persons would ordinarily be resident; or
- (ii) 4 or more single dwellings located on one allotment and used for short-term accommodation,

which are not located above or below another dwelling or another Class of building other than a *private garage*.

**Class 2**: a building containing 2 or more *sole-occupancy units* each being a separate dwelling.

**Class 3**: a residential building, other than a building of Class 1 or 2, which is a common place of long term or transient living for a number of unrelated persons, including:

- (a) a boarding-house, guest house, hostel, lodging house or backpackers accommodation; or
- (b) a residential part of a hotel or motel; or
- (c) a residential part of a *school;* or
- (d) accommodation for the aged, children or people with disabilities; or
- (e) a residential part of a *health-care building* which accommodates members of staff; or
- (f) a residential part of a detention centre.

**Class 4**: a dwelling in a building that is Class 5, 6, 7, 8 or 9 if it is the only dwelling in the building.

**Class 5:** an office building used for professional or commercial purposes, excluding building of Class 6, 7, 8, or 9.

**Class 6**: a shop or other building for the sale of goods by retail or the supply of services direct to the public, including -

- (a) an eating room, café, restaurant, milk or soft-drink bar; or
- (b) a dining room, bar area that is not an *assembly building*, shop or kiosk part of a hotel or motel; or
- (c) a hairdresser's or barber's shop, public laundry, or undertaker's establishment; or

(d) market or sale room, showroom, or service station.

Class 7: a building which is -

- (a) Class 7a a *carpark;* or
- (b) **Class 7b** for storage, or display of goods or produce for sale by wholesale.

**Class 8:** a laboratory, or a building in which a handicraft or process for the production, assembling, altering, repairing, packing, finishing, or cleaning of goods or products is carried on for trade, sale, or gain.

Class 9: a building of a public nature -

- (a) **Class 9a** a *health-care building*, including those parts of the building set aside as a laboratory; or
- (b) Class 9b an *assembly building*, including a trade workshop, laboratory or the like in a primary or secondary school, but excluding any other parts of the building that are of another Class; or
- (c) **Class 9c** an *aged care building*.

Class 10: a non-habitable building or structure -

- (a) **Class 10a** a non-habitable building being a *private garage*, carport, shed, or the like; or
- (b) **Class 10b** a structure being a fence, mast, antenna, retaining or freestanding wall, *swimming pool*, or the like.
- (c) **Class 10c** a private bushfire shelter.

#### A3.3 - Multiple Classifications

Each part of the building must be classified separately, and -

(a)

- (i) where parts have different purposes if not more than 10% of the *floor* area of a *storey*, being the minor use, is used for a purpose which is a different classification, the classification applying to the major use may apply to the whole *storey*; and
- (ii) the provisions of (i) do not apply when the minor use is a laboratory of Class 2,3 or 4 part; and

- (b) Classes 1a, 1b, 7a, 7b, 9a, 9b, 9c, 10a, 10b and 10c are separate classification; and
- (c) A reference to -
  - (i) Class 1 is to Class 1a and 1b; and
  - (ii) Class 7 is to Class 7a and 7b; and
  - (iii) Class 9 is to Class 9a, 9b and 9c; and
  - (iv) Class 10 is to Class 10a, 10b and 10c; and
- (d) A plant room, machinery room, lift motor room, boiler room or the like must have the same classification as the part of the building in which it is situated.

#### Part A3.4 - Parts with more than one classification

- (a) Notwithstanding A3.3, a building or part of a building may have more than one classification applying to the whole building or to the whole of that part of the building.
- (b) If a building or part of a building has more than one classification applying to the whole building or part in accordance with (a), that building or part must comply with all the relevant provisions of the BCA for each classification.

Terms in Italics have a specific meaning defined in the BCA (NCC)<sup>30</sup>.

<sup>&</sup>lt;sup>30</sup> Building Code of Australia (BCA), which is also referred to as the National Construction Code (NCC).

# **B** List of relevant standards in the AS/NZS Series

## B.1 AS/NZS 1680 Series – Building Lighting

A list of standards making up the AS/NZS 1680 series, and the areas specifying design values are provided below:

AS/NZS 1680.0 - Safe Movement

AS/NZS 1680.1 - General Principles and Recommendations

Section 3 – Task Visibility

AS/NZS 1680.2.1 - Specific Applications, Circulation Spaces and other General Areas

 Appendix D – Specific Recommendations for Circulation Spaces and Other General Areas

AS/NZS 1680.2.2 - Specific Applications, Office and Screen-based Tasks

 Appendix E – Specific Recommendations for Office and Screen-Based Visual Tasks

AS/NZS 1680.2.3 - Specific Applications, Educational and Training Facilities

 Appendix D – Specific Recommendations for Educational and Training Facilities

AS/NZS 1680.2.4 - Interior Lighting, Industrial Tasks and Processes

Appendix E – Specific Recommendations for Industrial Tasks and Processes

AS/NZS 1680.2.5 - Interior Lighting, Hospital and Medical Tasks

Appendix F – Specific Recommendations for Hospital and Medical Tasks

Please note that any values contained in any AS/NZS 1680.2 series Standard take precedence over AS/NZS 1680.1

AS/NZS 1680.3 - Measurement, calculation and presentation

AS/NZS 1680.4 - Lumen Maintenance

## B.2 AS/NZS 1158 Series – Lighting for Roads and Public Spaces

- ▼ AS/NZS 1158.0 Introduction
- AS/NZS 1158.1.1 Vehicular Traffic (Category V) lighting Performance and design requirements
- AS/NZS 1158.1.2 Vehicular Traffic (Category V) lighting Guide to design, installation, operation and maintenance
- AS/NZS 1158.2 Computer procedures for the calculation of light technical parameters for Category V and Category P lighting
- AS/NZS 1158.3.1 Pedestrian Area (Category P) lighting Performance and design requirements
- ▼ AS/NZS 1158.4 Lighting for Pedestrian crossings
- ▼ AS/NZS 1158.5 Tunnels and underpasses
- ▼ SA/SNZ TS 1158.6 Luminaires Performance

In order to demonstrate compliance with the standard, you must refer to the following parts:

- Appendix D of AS/NZS 1158.1.1 specifies the documentation required to demonstrate vehicular lighting (category V lighting) is compliant with the standard.
- ▼ Appendix E of AS/NZS 1158.3.1 specifies the documentation required to demonstrate pedestrian lighting (category P lighting) is compliant with the standard, and
- ▼ Appendix D of AS/NZS 1158.4 specifies the documentation required to demonstrate pedestrian crossing lighting (category PX) is compliant with the standard.

# C Equations and inputs to Commercial Lighting Energy Savings Formula calculations<sup>31</sup>

### **Equation 6**

For each Implementation:

Energy Savings = Baseline Energy Consumption - Upgrade Energy Consumption

Where:

#### **Baseline Energy Consumption, in MWh, is calculated:**

- using Equation 7, if the Lighting Upgrade is part of a refurbishment that would not have been required to comply with the BCA Part J6, had the Lighting Upgrade component of the refurbishment not occurred;
- using Equation 7 if the Lighting Upgrade is part of a refurbishment that would have been required to comply with the BCA Part J6, had the Lighting Upgrade component of the refurbishment not occurred and where the existing lighting meets or is below the maximum IPD requirements of the BCA Part J6; or
- using Equation 8 if the Lighting Upgrade is part of a refurbishment that would have been required to comply with the BCA Part J6, had the Lighting Upgrade component of the refurbishment not occurred, and where the existing lighting does not meet the IPD requirements of the BCA Part J6.

## **Equation 7**

Baseline Energy Consumption (MWh) =

```
\Sigma_{Each Incumbent Lamp} (LCP × Asset Lifetime × Annual Operating Hours × CM × AM) ÷ 10<sup>6</sup>
```

Where:

- *Each Incumbent Lamp* means each Lamp and Control Gear in the pre-existing lighting system;
- *LCP*, in Watts, is the default lamp circuit power corresponding to that type of Lamp and Control Gear for that End-User Equipment as set out in **Table A9.2** or **Table A9.4** of Schedule A to the ESS Rule, representing the power drawn by the Lamp, plus the losses of its Control Gear;

<sup>&</sup>lt;sup>31</sup> Extract of the ESS Rule 2009, as updated from time to time.

- Asset Lifetime, in years, is the default lifetime of the Lighting Upgrade for the relevant End-User Equipment as used in Equation 9;
- Annual Operating Hours, in hours/year, is the default number of hours per annum that the upgraded lighting system is expected to operate for the relevant building and space type as set out in Table A10.2 of Schedule A to the ESS Rule;
- *CM* is the control multiplier. If the Lamp is connected to a Control System, the factor for the control multiplier shall be applied for the relevant End-User Equipment or activity as set out in Table A10.4 of Schedule A to the ESS Rule, otherwise CM = 1.0; and.
- ▼ *AM* is the air-conditioning multiplier for the space as used in Equation 9.

#### **Equation 8**

#### Baseline Energy Consumption (MWh) =

$$\Sigma_{Each Space}$$
 (IPD × Area × Asset Lifetime × Annual Operating Hours × AM )  $\div$  106

Where:

- ▼ *Each Space* means each portion of space within the Site requiring a different IPD as defined in Part J6 of the BCA;
- IPD, in Watts/m<sup>2</sup>, is the maximum allowable IPD for each space, as required by Table J6.2b of the BCA. For simplicity, the Scheme Administrator may take a weighted average of similar IPDs in the Commercial Lighting Formula. The IPD should not be adjusted by the adjustment factors tabled in Table 6.2c of the BCA (Lighting Power Density Calculations: Adjustment);
- ▼ *Area*, in m<sup>2</sup>, is the area of Each Space;
- Asset Lifetime, in years, is the default lifetime of the Lighting Upgrade for the relevant End-User Equipment as used in Equation 9;
- *Annual Operating Hours*, in hours/year, is the default number of hours per annum that the upgraded lighting system is expected to operate for the relevant building and space type as set out in Table A10.2 of Schedule A to the ESS Rule; and
- ▼ *AM* is the air-conditioning multiplier for the space as used in Equation 9.

### **Equation 9**

Upgrade Energy Consumption (MWh) =

$$\Sigma_{Each Upgrade Lamp}$$
 (LCP × Asset Lifetime x Annual Operating Hours × CM × AM ) ÷10<sup>6</sup>

Where:

- ▼ *Each Upgrade Lamp* means each Lamp and Control Gear in the upgraded lighting system.
- *LCP*, in Watts, is the default lamp circuit power corresponding to that type of Lamp and Control Gear for that End-User Equipment as set out in **Table A9.2** or **Table A9.4** of Schedule A to the ESS Rule, representing the power drawn by the Lamp, plus the losses of its Control Gear.
- Asset Lifetime, in years, is the default lifetime of the Lighting Upgrade for the relevant End-User Equipment as set out in Table A10.1 of Schedule A to the ESS Rule, or another value accepted by the Scheme Administrator.
- *Annual Operating Hours*, in hours/year, is the default number of hours per annum that the upgraded lighting system is expected to operate for the relevant building and space type as set out in Table A10.2 of Schedule A to the ESS Rule.
- *CM* is the control multiplier. If the Lamp is connected to a Control System, the factor for the control multiplier shall be applied for the relevant End-User Equipment or activity as set out in Table A10.4 of Schedule A to the ESS Rule, otherwise CM = 1.0, and
- ▼ *AM* is the air-conditioning multiplier for the space, after Implementation, as set out in **Table A10.5** of Schedule A to the ESS Rule.

# D Tables from the ESS Rule

| Equipment Class  | Definition  |  |
|--|---|--|
| T12 linear fluorescent<br>Lamp   | A double-capped fluorescent Lamp as defined by <i>AS/NZS</i> 4782.1<br><i>Double-capped fluorescent lamps – Performance specifications</i> with a tube diameter of 38.1mm. These are also referred to as T38                                    |  |
| T8 linear fluorescent<br>Lamp  | A double-capped fluorescent Lamp as defined by AS/NZS 4782.1<br>Double-capped fluorescent lamps – Performance specifications with a<br>tube diameter of 25.4mm. These are also referred to as T26   |  |
| T5 linear fluorescent<br>Lamp  | A double-capped fluorescent Lamp as defined by AS/NZS 4782.1<br>Double-capped fluorescent lamps – Performance specifications with a<br>tube diameter of 15.9mm. These are also referred to as T16   |  |
| T5 or T8(T9) Circular<br>fluorescent Lamp  | A circular double-capped circular fluorescent Lamp with a typical tube diameter of 16mm or 29mm as defined by <i>AS/NZS</i> 4782.1 <i>Double-capped fluorescent lamps – Performance specifications</i> . These are also referred to as T9       |  |
| Compact fluorescent<br>Lamp with non-integrated<br>ballast (CFLn)                          | An externally ballasted single-capped fluorescent Lamp as defined by <i>AS/NZS 60901 Single-capped fluorescent lamps-Performance specifications</i> . The Lamp may include an internal means of starting and pre-heated cathodes.               |  |
| Compact fluorescent<br>Lamp with integrated<br>ballast (CFLi)                              | A Self-ballasted compact fluorescent Lamp as defined by AS/NZS 4847<br>Self-ballasted lamps for general lighting services   |  |
| Tungsten halogen Lamp<br>(240V)  | A Tungsten halogen Lamp as defined in <i>AS 4934 Incandescent lamps for general lighting service</i> , with a rated voltage of 240V.  |  |
| Tungsten halogen Lamp<br>(ELV)   | A Tungsten halogen Lamp as defined in <i>AS</i> 4934 <i>Incandescent lamps for general lighting service</i> , with a ELV rating, typically 12V. These amps run off an Extra-low voltage lighting converter (ELC) as defined in <i>AS</i> 4879.1 |  |
| Infrared coated (IRC)<br>halogen Lamp (ELV)  | A ELV Tungsten halogen Lamp as defined in <i>AS</i> 4934 where the halogen globe is coated with a reflective infrared coating this improves the efficiency of the globe.  |  |
| Metal halide Lamp  | A discharge Lamp classified as a Metal halide Lamp as defined by IEC 61167 Metal halide lamps – Performance specification   |  |
| Mercury vapour Lamp  | A discharge Lamp classified as a High-pressure mercury vapour Lamp<br>as defined by IEC 60188 High-pressure mercury vapour lamps –<br>Performance specifications  |  |
| High pressure sodium<br>(HPS) Lamp   | A discharge Lamp classified as a High pressure sodium vapour Lamp as defined by IEC 60662 High-pressure sodium vapour lamps   |  |
| Lighting for Roads and<br>Public Spaces or traffic<br>signals (other than LED<br>lighting) | Lighting for Roads and Public spaces as defined by AS 1158 Lighting for roads and public spaces   |  |

| Equipment Class   | Control Gear                    | LCP (Watts)      | Notes   |  |
|---|---------------------------------|------------------|---|--|
| T8 or T12 linear<br>fluorescent Lamp or<br>T8(T9) or T12 circular | Electronic ballast, EEI<br>= A1 | NLP + 2          | If EEI of Electronic<br>ballast is not known,<br>use EEI = A3 |  |
| fluorescent Lamp  | Electronic ballast, EEI<br>= A2 | NLP              |   |  |
|   | Electronic ballast, EEI<br>= A3 | NLP + 2          |   |  |
|   | Magnetic ballast, EEI = NLP + 6 |                  | If EEI of Magnetic<br>ballast is not known<br>use EEI = C     |  |
|   | Magnetic ballast, EEI =<br>B2   | NLP + 8          |   |  |
|   | Magnetic ballast, EEI =<br>C    | NLP + 10         |   |  |
|   | Magnetic ballast, EEI<br>= D    | NLP + 12         |   |  |
| T5 linear fluorescent<br>Lamp or T5 circular                      | p or T5 circular = A1           |                  | If EEI of Electronic<br>ballast is not known,<br>use EEI = A3 |  |
| fluorescent Lamp  | Electronic ballast, EEI<br>= A2 | 1.08 × NLP + 1.5 |   |  |
|   | Electronic ballast, EEI<br>= A3 | 1.13 × NLP + 2.5 |   |  |
| Compact fluorescent<br>Lamp with non-                             | Electronic ballast, EEI<br>= A1 | ballas           |   |  |
| integrated ballast<br>(CFLn)                                      | Electronic ballast, EEI<br>= A2 | NLP + 1          | use EEI = A3  |  |
|   | Electronic ballast, EEI<br>= A3 | NLP + 3          |   |  |
|   | Magnetic ballast, EEI =<br>B1   |                  | If EEI of Magnetic<br>ballast is not known<br>use EEI = C     |  |
|   | Magnetic ballast, EEI<br>= B2   | NLP + 7          |   |  |
|   | Magnetic ballast, EEI<br>= C    | NLP + 9          |   |  |
|   | Magnetic ballast, EEI<br>= D    | NLP + 11         |   |  |
| Compact fluorescent<br>Lamp with integrated<br>ballast (CFLi)     | Built In                        | NLP              |   |  |

Table A9.2: Lamp Circuit Power (LCP) values for Standard Equipment Classes

| Equipment Class  | Control Gear                                | LCP (Watts)  | Notes   |  |
|--|---|--|---|--|
| Tungsten halogen<br>Lamp (240V)  | Built In                                    | NLP  |   |  |
| Tungsten halogen<br>Lamp (ELV) or Infrared   | Magnetic transformer                        | 1.25 × NLP   | Maximum NLP of<br>removed Lamp =<br>35W   |  |
| coated (IRC) halogen<br>Lamp (ELV)   | Electronic transformer                      | 1.08 × NLP   |   |  |
| Metal halide Lamp  | Magnetic ballast<br>(reactor type)          | 1.05 × NLP + 14  |   |  |
|  | Magnetic ballast<br>(constant wattage type) | 1.07 × NLP + 22  |   |  |
|  | Electronic ballast                          | 1.10 × NLP + 0.9   |   |  |
| Mercury vapour Lamp  | Magnetic ballast                            | 1.03 × NLP + 11  |   |  |
| High pressure sodium<br>(HPS) Lamp   | Magnetic ballast                            | 1.05 × NLP + 13  |   |  |
| Lighting for Roads and<br>Public Spaces or traffic<br>signals (other than LED<br>lighting) | Built in or Independent                     | Lighting Load Table<br>Published by AEMO<br>or relevant regulator. | An entire traffic<br>signal unit or<br>Integrated Luminaire<br>is used as the basis<br>for calculation, rather<br>than individual<br>Lamps. |  |

| Equipment Class                           | Definition  |
|---|---|
| T5 adaptor kit                            | Any equipment that enables a T8 or T12 Luminaire to accommodate or provide physical support to a T5 Lamp or Luminaire.  |
| Retrofit Luminaire -<br>LED Linear Lamp   | A T5, T8 or T12 Luminaire that has been retrofitted with an LED linear<br>Lamp in place of the linear fluorescent Lamp. This cannot involve<br>modification to the wiring of the Luminaire other than removal,<br>replacement or modification of the starter.   |
| LED Lamp Only –<br>ELV                    | A LED Lamp that runs off an existing Extra-low voltage lighting converter (ELC) designed for retrofitting into an existing Luminaire or Lamp holder.<br>These are typically used as a replacement for ELV Tungsten halogen Lamps  |
| LED Lamp Only –<br>240V Self<br>Ballasted | A self-ballasted LED Lamp as defined by IEC 62560 Self-ballasted LED lamps for general lighting services by voltage > 50 V. These Lamps are connected directly to a 240V supply.  |
| Induction<br>Luminaire                    | A gas discharge Lamp in which the power required to generate light is transferred from outside the Lamp envelope to the gas via electromagnetic induction.  |
| LED Lamp and<br>Driver                    | A LED-reflector Lamp and matching LED Driver intended as an<br>alternative to a Mirrored Reflector Halogen Lamp   |
| Modified Luminaire<br>–LED Linear Lamp    | A T5, T8 or T12 luminaire that has been modified for use with an LED linear Lamp. This involves modifying, removing or rendering redundant any wiring or structure of the Luminaire, beyond the replacement of a starter.   |
| LED Luminaire –<br>fixed type             | A LED Luminaire intended for use as a fixed luminaire as defined in AS/NZS 60598.2.1 Luminaires – Particular requirements – Fixed general purpose luminaires  |
| LED Luminaire –<br>Linear Lamp            | An LED Luminaire intended for use as an alternative to a linear<br>fluorescent Luminaire, where the Luminaire houses a matching Linear<br>LED tube or a linear array of integrated LEDs. Where the Luminaire<br>uses a Linear LED tube, the Luminaire must not be compatible with a<br>linear fluorescent Lamp. |
| LED Luminaire –<br>floodlight             | A LED Luminaire intended for use as a floodlight as defined in AS/NZS 60598.2.5 Luminaires – Particular requirements - Floodlights  |
| LED Luminaire –<br>recessed               | A LED Luminaire intended for use as a recessed luminaire as defined in AS/NZS 60598.2.2 Luminaires – Particular requirements – Recessed luminaires  |
| LED Luminaire –<br>high/lowbay            | A LED Luminaire intended for use as high-bay or low-bay lighting  |
| LED Luminaire –<br>streetlight            | A LED Luminaire intended for use as a streetlight as defined in AS/NZS 60598.2.3 Particular requirements – Luminaires for road and street lighting  |
| LED Luminaire –<br>emergency lighting     | A LED Luminaire intended for use as an Emergency lighting luminaire as defined in AS/NZS 60598.2.22 Particular requirements – Luminaires for emergency lighting   |

Table A9.3: Other Equipment Classes for Lighting Upgrades

| Equipment Class                          | Definition  |
|--|---|
| LED Luminaire –<br>hospital use          | A LED Luminaire intended for use in the clinical areas of a hospital or<br>health care building as defined in AS/NZS 60958.2.25 Particular<br>requirements – Luminaires for use in clinical areas of hospitals and<br>health care buildings |
| Other Emerging<br>Lighting<br>Technology | Any lighting equipment not defined above.   |

| Equipment Class                      | Control Gear                                  | LCP Value                                       | Equipment Requirement  |
|--------------------------------------|---|---|--|
| T5 Adaptor Kit                       | Not Applicable (ineligible)                   | Not Applicable (ineligible)                     | Ineligible   |
| Retrofit Luminaire - LED Linear Lamp | Not Applicable(ineligible)                    | Not Applicable (ineligible)                     | Ineligible   |
| LED Lamp Only – ELV                  | Built In + Existing<br>Magnetic Transformer   | 1.25 × NLP as Published by Scheme Administrator | Must meet product requirements and minimum performance<br>specifications for Lamp Life, electro-magnetic compatibility (where<br>applicable), lumen efficacy, power factor, LCP, and any other |
|                                      | Built In + Existing<br>Electronic Transformer | 1.08 × NLP as Published by Scheme Administrator | requirements as Published by the Scheme Administrator, as<br>evidenced by:   |
| LED Lamp Only – 240V Self Ballasted  | Built In                                      | As Published by the Scheme                      | a) a certification scheme accepted by the Scheme Administrator;  |
| Induction Luminaire                  | Built In or Independent                       | Administrator                                   | and  |
| LED Lamp and Driver                  |   |   | b) test reports from an accredited laboratory, in accordance with requirements Published by the Scheme Administrator; or   |
| Modified Luminaire- LED Linear Lamp  |   |   | requirements Published by the Scheme Administrator, or   |
| LED Luminaire – fixed type           |   |   | c) compliance with a relevant AS/NZS standard for the relevant<br>Equipment Class recognised by the Scheme Administrator; or   |
| LED Luminaire – Linear Lamp          |   |   | d) demonstrated product acceptance under schedules of the VEET   |
| LED Luminaire – floodlight           |   |   | scheme recognised as relevant by the Scheme Administrator  |
| LED Luminaire – recessed             |   |   | including compliance with any additional Equipment<br>Requirements Published by the Scheme Administrator.  |
| LED Luminaire – high/lowbay          |   |   |  |
| LED Luminaire – streetlight          |   |   |  |
| LED Luminaire – emergency lighting   |   |   |  |
| LED Luminaire – hospital use         |   |   |  |
| Other Emerging Lighting Technology   |   |   |  |

# Table A9.4: Lamp Circuit Power (LCP) values and Equipment Requirements for other Equipment Classes for Lighting Upgrades

| Table A9.5: | Control | gear for | Lighting | Upgrades |
|-------------|---------|----------|----------|----------|
|-------------|---------|----------|----------|----------|

| Control Gear                                | Definition   |
|---|--|
| Magnetic ballast                            | A Ferromagnetic ballast as defined in AS/NZS 4783 Performance of electrical lighting equipment – Ballasts for fluorescent lamps  |
| Electronic ballast                          | An A.C. supplied electronic ballast as defined in <i>AS/NZS</i> 4783<br>Performance of electrical lighting equipment – Ballasts for<br>fluorescent lamps   |
| Magnetic ballast (reactor type)             | An electromagnetic ballast that use an inductor or autotransformer<br>to limit the current and provide the voltage necessary to ignite the<br>Lamp. These ballasts do not include any means of regulating the<br>light output. |
| Magnetic ballast<br>(constant wattage type) | An electromagnetic ballast that uses a combination of inductive<br>and capacitive components to provide a regulated power output<br>(constant wattage) to the Lamp   |
| Magnetic transformer                        | A magnetic isolating transformer as defined in AS/NZS 4879.1<br>Performance of transformers and electronic step-down convertors<br>for ELV lamps - Test method - Energy performance.   |
| Electronic transformer                      | An electronic step-down convertor as defined in AS/NZS 4879.1<br>Performance of transformers and electronic step-down convertors<br>for ELV lamps - Test method - Energy performance.  |

### Table A9.6: Default Lamp Life for Lighting Upgrades

| Type of Lamp                                     | Lamp Life (hours)                         |
|--|---|
| Standard equipment classes defined in Table A9.1 | As per product labelling.                 |
| Other equipment classes defined in Table A9.3    | As Published by the Scheme Administrator. |

| Activity   | Asset Lifetime (years)   |  |
|--|--|--|
| Replacement of :<br>▼ Luminaire, or<br>▼ Control Gear (not integrated into Lamp).  | Lighting for Roads and Public Spaces or<br>traffic signals: 12 years<br>All other lighting: 10 years   |  |
| Replacement of:<br>Lamp Only.  | Lamp Life ÷ Annual Operating Hours<br>(Where Lamp Life is measured in accordance<br>with Table A9.6 and is a maximum of 30,000<br>hours)<br>Maximum Asset Lifetime = 10 years for<br>Buildings and 12 years for Lighting for Roads<br>and Public Spaces or traffic signals |  |
| Installation of:<br>Control System as listed in Table A10.4<br>where the Lighting Upgrade only consists of<br>the installation of a Control System | Maximum Asset Lifetime = 5 years   |  |

Table A10.1: Asset Lifetimes for Lighting Upgrades

# Table A10.2: Operating Hours for Lighting Upgrades by space type

| Space Type  | Annual Operating Hours<br>(hours per annum)                                 |
|---|---|
| Auditorium, church and public hall  | 2,000   |
| Board room and conference room  | 3,000   |
| Carpark – general (undercover) and Car Park - entry zone (first 20 m of travel) | 7,000   |
| Carpark – general (open air)  | 4,500   |
| Common rooms, spaces and corridors in a Class 2 building                        | 7,000   |
| Control room, switch room, and the like   | Value in Table A10.3 for BCA<br>Classification of the<br>surrounding space  |
| Corridors   | Value in Table A10.3 for BCA<br>Classification of the<br>surrounding space  |
| Courtroom   | 2,000   |
| Dormitory of a Class 3 building used for sleeping only or sleeping and study    | 3,000   |
| Entry lobby from outside the building   | Value in Table A10.3 for BCA<br>Classification of the<br>surrounding space. |

| Space Type  | Annual Operating Hours<br>(hours per annum)                                |
|---|--|
| Health-care - children's ward, examination room, patient ward, all patient care areas including corridors where cyanosis lamps are used | 6,000  |
| Kitchen and food preparation area   | Value in Table A10.3 for BCA<br>Classification surrounding<br>space        |
| Laboratory - artificially lit to an ambient level of 400 lx or more   | 3,000  |
| Library - stack and shelving area, reading room and general areas   | 3,000  |
| Lounge area for communal use in a Class 3 building or<br>Class 9c aged care building  | 7,000  |
| Maintained Emergency Lighting   | 8,500  |
| Museum and gallery - circulation, cleaning and service lighting   | 2,000  |
| Office  | 3,000  |
| Plant room  | Value in Table A10.3 for BCA<br>Classification of the<br>surrounding space |
| Restaurant, café, bar, hotel lounge and a space for the serving and consumption of food or drinks                                       | 5,000  |
| Retail space including a museum and gallery whose purpose is the sale of objects  | 5,000  |
| School - general purpose learning areas and tutorial rooms  | 3,000  |
| Sole-occupancy unit of a Class 3 building   | 3,000  |
| Sole-occupancy unit of a Class 9c aged care building  | 6,000  |
| Storage with shelving no higher than 75% of the height of the aisle lighting  | 5,000  |
| Storage with shelving higher than 75% of the height of the aisle lighting   | 5,000  |
| Service area, cleaner's room and the like   | Value in Table A10.3 for BCA<br>Classification of the<br>surrounding space |
| Toilet, locker room, staff room, rest room and the like   | Value in Table A10.3 for BCA<br>Classification of the<br>surrounding space |
| Wholesale storage and display area  | 5,000  |

| Space Туре                     | Annual Operating Hours<br>(hours per annum)             |
|--------------------------------|---|
| Other spaces not defined above | Value in Table A10.3 for BCA<br>Classification of space |

# Table A10.3: Annual Operating Hours for Lighting Upgrades by building type

| Building Classification   | Annual Operating<br>Hours (hours per<br>annum) |
|---|--|
| BCA Class 2 buildings (Common Areas)                                | 7,000  |
| BCA Class 3 buildings (Common Areas)                                | 7,000  |
| BCA Class 3 buildings (other than Common Areas)                     | 3,000  |
| BCA Class 5 buildings   | 3,000  |
| BCA Class 6 buildings   | 5,000  |
| BCA Class 7 buildings   | 5,000  |
| BCA Class 7 (a) buildings (open air car parks)                      | 4,500  |
| BCA Class 7 (a) buildings (undercover car parks)                    | 7,000  |
| BCA Class 8 buildings (other than ANZSIC Division C, Manufacturing) | 3,000  |
| BCA Class 8 buildings (ANZSIC Division C, Manufacturing)            | 5,000  |
| BCA Class 9a and 9c buildings                                       | 6,000  |
| BCA Class 9b buildings  | 2,000  |
| BCA Class 10b buildings   | 1,000  |
| Roads and Public Spaces   | 4,500  |
| Traffic Signals   | 8,760  |

| Control System                      | Definition   | Control<br>Multiplier (CM)                |
|-------------------------------------|--|---|
| Occupancy<br>Sensor                 | Control device that uses a motion sensor to detect the presence of people in the Space and adjusts the light output of the Luminaire. Each Occupancy Sensor must control a maximum of 6 Luminaires.                        | 0.7                                       |
| Daylight-Linked<br>Control          | Control device that uses a photoelectric cell to measure<br>ambient daylight levels to automatically vary Luminaire light<br>output. Each Luminaire must be located close to a significant<br>source of daylight.          | 0.7                                       |
| Programmable<br>Dimming             | Luminaire light output controlled by pre-selected light levels<br>(scenes) which are automatically selected according to time of<br>day, photoelectric cell and/or Occupancy Sensor. Scenes<br>must reduce lighting power. | 0.85                                      |
| Manual Dimming                      | Control device that allows a user to control Luminaire light<br>output using a knob, slider or other manual input mechanism<br>or by manually selecting a pre-programmed light level (scene).                              | 0.9                                       |
| Multiple Control                    | Programmable Dimming and Manual Dimming  | 0.76                                      |
| Systems                             | Any other combination of 2 or more control systems above.  | 0.6                                       |
| Voltage<br>Reduction Units<br>(VRU) | A control device that reduces the voltage applied to the Luminaire after start-up, when used with appropriate Luminaires.  | As approved by<br>Scheme<br>Administrator |

### Table A10.4: Control Systems and Control Multipliers for Lighting Upgrades

# Table A10.5: Air-conditioning Multipliers for Lighting Upgrades

| Air-conditioning system | Air-conditioning Multiplier (AM) |
|-------------------------|----------------------------------|
| Air-conditioned         | 1.3                              |
| Not air-conditioned     | 1                                |

# Table A17: End-Use Services

| End-Use Services  |
|---|
| Air heating and cooling   |
| Air handling, fans, ventilation                                 |
| Water heating   |
| Water/liquid pumping  |
| Refrigeration and freezing                                      |
| Lighting  |
| Cooking   |
| Home entertainment  |
| Computers, office equipment                                     |
| Communications  |
| Cleaning, washing   |
| Process heat  |
| Air compression   |
| Process drives  |
| Milling, mixing, grinding                                       |
| Transport   |
| People movement, lifts, escalators                              |
| Materials handling, conveying                                   |
| Other machines  |
| Electricity supply  |
| Unknown   |
| Other End-Use Services as Published by the Scheme Administrator |

| Business Classification                           | Economic Sector |
|---|-----------------|
| A Agriculture, Forestry and Fishing               | Industrial      |
| B Mining  | Industrial      |
| C Manufacturing                                   | Industrial      |
| D Electricity, Gas, Water and Waste Services      | Industrial      |
| E Construction                                    | Industrial      |
| F Wholesale Trade                                 | Commercial      |
| G Retail Trade                                    | Commercial      |
| H Accommodation and Food Services                 | Commercial      |
| I Transport, Postal and Warehousing               | Industrial      |
| J Information Media and Telecommunications        | Commercial      |
| K Financial and Insurance Services                | Commercial      |
| L Rental, Hiring and Real Estate Services         | Commercial      |
| M Professional, Scientific and Technical Services | Commercial      |
| N Administrative and Support Services             | Commercial      |
| O Public Administration and Safety                | Commercial      |
| P Education and Training                          | Commercial      |
| Q Health Care and Social Assistance               | Commercial      |
| R Arts and Recreation Services                    | Commercial      |
| S Other Services                                  | Commercial      |
| Residential                                       | Residential     |
| Unknown   | Unknown         |

# **Table A18: Business Classifications**