

Do you have any comments on the format of the Method Guide?

Activity definition HVAC1

In this activity, this document did not mention the problem of capacity matching. Product that the rated cooling capacity of the product should equal (or close) to the rated total cooling capacity of the decommissioned product. For examples, the power of existing air conditioner is 4kW, customers are interested in the 6kW air conditioner, how to calculate Certificates?

Meanwhile, the AEER should be applied instead of EER. *AEER means annual energy efficiency ratio; EER means energy efficiency ratio.* Normally, AEER is more accurate than EER, when describing the performance of air conditioners.

And, In the table 1.1,1.2,1.4 from the schedule B, data (baseline cooling EER, and minimum requirement EER) should agree with table D16.2, D16.3, D16.5 in the *energy savings scheme (Amendment No.1) Rule 2022.*